

**SUPERVISORY SWITCHES**

Used to monitor the Open Position of an OS & Y, Butterfly or Post Indicator valve.



Figure No. 8150

**STANDARD EQUIPMENT:**

- 8150** OS & Y Supervisory Switch - 1" to 12"  
Two SPDT Switches.
- 8152** Butterfly or Post Indicator Switch.  
Two SPDT Switches.

**U/L LISTED - FM Approved - BSA Approved**

**EXPLOSION PROOF MODELS AVAILABLE**



Figure No. 8152

**ALARM BELLS**

Actuated by supervisory equipment in sprinkler and or standpipe systems Painted RED.



Figure No. 8154

<b>8154</b>	6" 24 VDC
<b>8156</b>	8" 24 VDC
<b>8158</b>	10" 24 VDC
<b>8160</b>	6" 120 VAC
<b>8162</b>	8" 120 VAC
<b>8164</b>	10" 120 VAC

**PLUG TYPE SUPERVISORY SWITCH**

**Figure 8165** plug type is used to monitor the condition of sprinkler system control valves. Designed for special applications on certain types of valves such as non-rising stem gate valves, ball valves and gate valves.



Figure No. 8165

**WATER FLOW DETECTORS**

Vane-Type Waterflow detector to detect the flow of water in wet pipe sprinkler and standpipe systems and signal the central control panel as this occurs. For schedule 10 or 40 Pipe. Static pressure Rating 175 PSI.



Figure No. 8180

<b>8180</b> - 1"	<b>8185</b> - 3"
<b>8181</b> - 1 1/4"	<b>8186</b> - 4"
<b>8182</b> - 1 1/2"	<b>8187</b> - 5"
<b>8183</b> - 2"	<b>8188</b> - 6"
<b>8184</b> - 2 1/2"	<b>8189</b> - 8"

Specify Schedule 10 or Schedule 40 when ordering.

**U/L LISTED- FM APPROVED - BSA APPROVED**

**EXPLOSION PROOF MODELS AVAILABLE**



Figure No. 8186